



November 16, 2009

Mr. Mai Huynh  
JM Eagle  
5200 W Century Blvd.  
Los Angeles, CA 90045

RE: **Project 9081528** – Annex G Review for JM Eagle Potable Water Pipe

Dear Mr. Mai Huynh,

This letter is to inform you, per your request on November 13, 2009, the following products Listed under Standard 14 and NSF Standard 61 for potable water applications have been reviewed against NSF/ANSI Standard 61, Annex G:

- JM Eagle PVC Pipe  $\geq \frac{1}{2}$ "
- Solid Wall PEX Tubing  $\frac{1}{8}$ " – 6"
- 5-Layer PEX Tubing  $\frac{1}{2}$ " – 1"
- PE Molded Fittings  $\geq \frac{1}{2}$ "
- PE Pipe  $\geq \frac{1}{2}$ "

Subsequent to this review, the following footnote will be added to the Official Listings for the above products:

*[G] Product also Certified to NSF/ANSI Standard 61, Annex G (weighted average lead content of  $\leq 0.25\%$ ) and is in compliance with California's Health & Safety Code Section 116875 (commonly known as AB1953).*

For additional information regarding Annex G, please visit [www.nsf.org/info/annexg](http://www.nsf.org/info/annexg).

It has been my pleasure to assist you with this project. As always, if you have any questions or concerns, please feel free to contact me.

Sincerely,

*Brandon Rudolph*

Brandon Rudolph  
Certification Project Manager  
Plumbing Products Certification

Phone: (734) 827-6826  
Fax: (734) 827-6114  
email: [brudolph@NSF.org](mailto:brudolph@NSF.org)