



Certificate of Compliance

This certificate is issued for the following:

Polyethylene (PE) Pipe for Underground Fire Protection Service

<i>Product Designation</i>	<i>Nominal Pipe Size, in.</i>	<i>Pressure Rating, psi (kPa)</i>
SDR11 Class 200 Pipe	4, 6, 8, 10, 12, 14, 16, 18, 20, 22, 24	200 (1380)
SDR9 Class 250 Pipe	4, 6, 8, 10, 12, 14, 16, 18, 20, 22, 24	250 (1725)
SDR7 Class 335 Pipe	4, 6, 8, 10, 12, 14, 16, 18, 20, 22, 24	335 (2310)

Prepared for:

JM Manufacturing Co., Inc. / dba JM Eagle Inc.
5200 West Century Blvd.
Los Angeles, CA 90045
United States

Manufactured at:

JM Eagle Inc.
4620 Olympic Drive
Kingman, AZ 86401
United States

FM Approvals Class: 1613, dated December 2017

Approval Identification: PR450956

Approval Granted: July 1, 2019

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink, appearing to read "D.B. Fuller", written over a horizontal line.

David Fuller
VP - Manager of Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062 USA



Member of the FM Global Group